

TABLE 5- WINDOW SYSTEM DESIGN RESULTS^
(ADV-062 VERTICAL&HORIZONTAL STIFFENER, ADV-053 HEAD, ADV-054 SILL, ADV-080 INTERNAL REVEAL#2)

Girt Spacing (mm)	Window Dimension (mm)	Away From Corner										Within 1200mm of Corners									
		Wind Category										Wind Category									
		N1	N2	N3	N4	N5	N6	C1	C2	C3	C4	N1	N2	N3	N4	N5	N6	C1	C2	C3	C4
800	740x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
800	740x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
800	740x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
800	740x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
800	740x1731	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
900	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
900	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
900	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
900	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
900	790x1731	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1000	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1000	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1000	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1000	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1000	790x1731	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1100	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1100	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1100	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1100	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1100	790x1731	P	P	P	P	P	P	P	P	P	P	P	P	P	F	P	P	P	P	F	
1200	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1200	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1200	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1200	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1200	790x1731	P	P	P	P	P	P	P	P	P	P	P	P	P	F	P	P	F	P	F	
1300	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1300	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1300	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1300	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1300	790x1731	P	P	P	P	P	P	P	P	F	P	P	P	P	F	F	P	P	F	F	
1400	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1400	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1400	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1400	790x1505	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1400	790x1731	P	P	P	P	P	P	P	P	F	P	P	P	P	F	F	P	P	F	F	
1500	790x589	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1500	790x816	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	
1500	790x1274	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	F	
1500	790x1505	P	P	P	P	P	P	P	P	F	P	P	P	P	P	F	P	P	F	F	
1500	790x1731	P	P	P	P	P	P	P	P	F	P	P	P	P	F	F	P	P	F	F	

NOTE: P "PASSED" - Indicates that corresponding window size satisfies the strength and serviceability requirements.
F "FAILED" - Indicates that corresponding window size do not satisfy the strength and serviceability requirements.

(A) This window system consists of head, sill, vertical stiffeners (Jambs) and horizontal stiffeners that provide additional support behind the head and sill. The Internal Reveal is used together with horizontal and vertical stiffeners.

THIS MATRIX TABLE **DOES NOT** MAKE ANY ALLOWANCE REGARDING STRUCTURAL CAPACITY/ADEQUACY OF THE SHED WALL CLADDING, GIRTS AND OTHER WALL FRAMING MEMBERS. THESE MUST BE DESIGNED AND CERTIFIED BY THE SHED DESIGN ENGINEER.

Ultimate Strength Wind Pressures (According to AS4055-2006 Table 3.3)

Walls		Wind Class									
		N1	N2	N3	N4	N5	N6	C1	C2	C3	C4
Away From Corners	kPa	0.69	0.96	1.50	2.23	3.29	4.44	-2.03	-3.01	-4.44	-5.99
Within 1200mm of Corners	kPa	-1.04	-1.44	-2.25	-3.35	-4.93	-6.66	-3.00	-4.47	-6.57	-8.88

Member	Alloy and Temper
Horizontal Stiffener (ADV-062)	6106-T6
Vertical Stiffener (ADV-062)	6106-T6
Head (ADV-053)	6106-T6
Sill (ADV-054)	6063-T6
Face Infill (ADV-040)	6063-T6
Internal Reveal#2 (ADV-080)	6063-T6